

DATA SI ORA PRELEVAREII	Sector/Centrul ZAP/ PUNCT DE PRELEVARE	INDICATOR ANALIZAT	U.M	VALORI DETERMINATE	Incertitudinea extinsa relativa k=2, p95% [%]	VAL. ADMISA conf. Ordonantei nr. 7/2023	METODA DE INCERCARE
11.08.2026/09 ³⁰	Zona Metropolitana- ZAP Buzau Consumator Sursa Crang	Nitriti	mg/l	<0,015 (IQ)	±10 %	0.500	SR EN 26777:2002; SR EN 26777:2002/C91:2006
		Azotati	mg/l	34,318	±10 %	50.000	SR ISO 7890-3:2000
		Conductivitate	µS/cm	1411 (20.6 °C)	±5 %	2500	SR EN 27888:1997
		Amoniu	mg/l	<0,036 (IQ)	±10 %	0.500	SR ISO 7150-1:2001
		Clor residual liber	mg/l	0.30	±12 %	≥0,10; ≤0,50 in retea	SR EN ISO 7393-1:2002
		pH	unit. pH	7,59 (20.5 °C)	±0,10	≥6,50; ≤9,50	SR EN ISO 10523:2012
		Turbiditate	NTU	1,30	-	Acceptabila pentru consumatori si fara modificari anormale	SR EN ISO 7027-1:2016
		Miros	-	acceptabil	-	Acceptabil pentru consumatori si fara modificari anormale	SR EN 1622:2007-Anexa C
		Culoare	-	acceptabil	-	Acceptabila pentru consumatori si fara modificari anormale	SR EN ISO 7887:2012- Metoda A
		Numar de colonii la 22°C (nr. UFC/ml)	nr. UFC/ml	23	-	Fara modificari anormale	SR EN ISO 6222:2004
		Numar de colonii la 37°C (nr. UFC/ml)	nr. UFC/ml	2	-	Fara modificari anormale	SR EN ISO 6222:2004
		Bacterii coliforme (nr UFC/100 ml)	nr. UFC /100 ml	0	-	0	SR EN ISO 9308-1:2015; SR EN ISO 9308- 1:2015/A1:2017
		<i>Escherichia coli</i> (nr UFC/100 ml)	nr. UFC /100 ml	0	-	0	SR EN ISO 9308-1:2015; SR EN ISO 9308- 1:2015/A1:2017
		Enterococi intestinali (nr UFC/100 ml)	nr. UFC /100 ml	0	-	0	SR EN ISO 7899-2:2002

DATA SI ORA PRELEVARE	Sector/Centrul ZAP/ PUNCT DE PRELEVARE	INDICATOR ANALIZAT	U.M	VALORI DETERMINATE	Incertitudinea extinsa relativa k=2, P95% [%]	VAL. ADMISA conf. Ordonantei nr. 7/2023	METODA DE INCERCARE
11.08.2026/10 ⁰⁰	Zona Metropolitana- ZAP Buzau Consumator Sursa Zahar	Nitriti	mg/l	<0,015 (LQ)	±10 %	0,500	SR EN 26777:2002; SR EN 26777:2002/C91:2006
		Azotati	mg/l	17,488	±10 %	50,000	SR ISO 7890-3:2000
		Conductivitate	µS/cm	1214 (20,0 °C)	±5 %	2500	SR EN 27888:1997
		Amoniu	mg/l	<0,036 (LQ)	±10 %	0,500	SR ISO 7150-1:2001
		Clor rezidual liber	mg/l	0,30	±12 %	≥0,10; ≤0,50 in retea	SR EN ISO 7393-1:2002
		pH	unit. pH	7,92 (20,4 °C)	±0,10	≥6,50; ≤9,50	SR EN ISO 10523:2012
		Turbiditate	NTU	0,33	-	Acceptabila pentru consumatori si fara modificari anormale	SR EN ISO 7027-1:2016
		Fier total	mg/l	<0,060 (LQ)	±20 %	0,200	SR 13315:1996; SR 13315:1996/C91:2008
		Miros	-	acceptabil	-	Acceptabil pentru consumatori si fara modificari anormale	SR EN 1622:2007-Anexa C
		Culoare	-	acceptabil	-	Acceptabila pentru consumatori si fara modificari anormale	SR EN ISO 7887:2012- Metoda A
		Numar de colonii la 22°C (nr. UFC/ml)	nr. UFC/ml	11	-	Fara modificari anormale	SR EN ISO 6222:2004
		Numar de colonii la 37°C (nr. UFC/ml)	nr. UFC/ml	5	-	Fara modificari anormale	SR EN ISO 6222:2004
		Bacterii coliforme (nr. UFC/100 ml)	nr. UFC /100 ml	0	-	0	SR EN ISO 9308-1:2015; SR EN ISO 9308- 1:2015/A1:2017
		<i>Escherichia coli</i> (nr. UFC/100 ml)	nr. UFC /100 ml	0	-	0	SR EN ISO 9308-1:2015; SR EN ISO 9308- 1:2015/A1:2017
		Enterococi intestinali (nr. UFC/100 ml)	nr. UFC /100 ml	0	-	0	SR EN ISO 7899-2:2002

DATA SI ORA PRELEVARII	Sector/Centru- ZAP/ PUNCT DE PRELEVARE	INDICATOR ANALIZAT	U.M	VALORI DETERMINATE	Incertitudinea extinsa relativa k=2, p95% [%]	VAL. ADMISA conf. Ordonantei nr. 7/2023	METODA DE INCERCARE
20.08.2026/09 ⁴⁵	Zona Metropolitana- ZAP Buzau Consumator Sursa Crang	Nitriti	mg/l	<0,015 (LO)	±10 %	0,500	SR EN 26777:2002; SR EN 26737:2007/C91:2006
		Azotati	mg/l	30,117	±10 %	50,000	SR ISO 7890-3:2000
		Conductivitate	µS/cm	1554 (19,5 °C)	±5 %	2500	SR EN 27888:1997
		Amoniu	mg/l	<0,036 (LO)	±10 %	0,500	SR ISO 7150-1:2001
		Clor rezidual liber	mg/l	0,40	±12 %	≥0,10; ≤0,50 in retea	SR EN ISO 7393-1:2002
		pH	unit. pH	7,36 (19,2 °C)	±0,10	≥6,50; ≤9,50	SR EN ISO 10523:2012
		Turbiditate	NTU	0,50	-	Acceptabila pentru consumatori si fara modificari anormale	SR EN ISO 7027-1:2016
		Miros	-	acceptabil	-	Acceptabil pentru consumatori si fara modificari anormale	SR EN 1622:2007-Anexa C
		Culoare	-	acceptabil	-	Acceptabila pentru consumatori si fara modificari anormale	SR EN ISO 7887:2012- Metoda A
		Numar de colonii la 22°C (nr. UFC/ml)	nr. UFC/ml	10	-	Fara modificari anormale	SR EN ISO 6222:2004
		Numar de colonii la 37°C (nr. UFC/ml)	nr. UFC/ml	6	-	Fara modificari anormale	SR EN ISO 6222:2004
		Bacterii coliforme (nr UFC/100 ml)	nr. UFC /100 ml	0	-	0	SR EN ISO 9308-1:2015; SR EN ISO 9308- 1:2015/A1:2017
		<i>Escherichia coli</i> (nr UFC/100 ml)	nr. UFC /100 ml	0	-	0	SR EN ISO 9308-1:2015; SR EN ISO 9308- 1:2015/A1:2017
		Enterococi intestinali (nr UFC/100 ml)	nr. UFC /100 ml	0	-	0	SR EN ISO 7899-2:2002